


## Test Verification of Conformity


On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address	: Shenzhen SOFARSOLAR Co., Ltd. 3A-1, Huake Building, East Technology Park, Qiaoxiang Road, Nanshan District, Shenzhen, China
Product(s) Tested	: Grid-connected PV inverter
Ratings and principal characteristics	: Maximum d.c. input voltage: 1000 V Input voltage rang: 250-960 V Max. Input current: 2×15 A Max. PV Isc: 2×20 A Nominal Grid voltage: 3/N/PE230V/400V Max. Output current: 3×15 A Nominal Grid frequency: 50 Hz Max. Output power: 10000 W Ingress protection: IP65 Operating temperature range: -25~60°C
Model(s)	: Sofar 10000TL-Sx (x=0-6)
Brand name	: 
Relevant Standard(s)/Specification(s)	: EN 50438: 2013, Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks Type Verification for Denmark
Verification Issuing Office Name & Address	: Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China
Date of Test(s)	: 27 Mar 2014 – 09 May 2014
Verification/Report Number(s)	: 140327083GZU-011 /140327083GZU-011

**NOTE :** This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Signature 

Name: Grady Ye  
Position: Sr. Supervisor  
Date: 30 May 2014