



**BUREAU  
VERITAS**

## ATTESTATION

# of conformity with European Directives

Attestation Number: **2088AB0709N001005**

Product: **Solar grid-tied inverter**

Brand Name: 

Model: **AZZURRO 1PH 3000TLM-V1, AZZURRO 1PH 4000TLM-V1,**

**AZZURRO 1PH 5000TLM-V1, AZZURRO 1PH 6000TLM-V1,**

Additional Model: **AZZURRO 1PH 3680TLM-V1, AZZURRO 1PH 4600TLM-V1**

Applicant: **Zucchetti Centro Sistemi SpA**

Address: **Via Lungarno 305/A 52028 Terranuova Bracciolini (AR) Italy**

Technical

Characteristics:

**DC Input: DC 100 - 550V, 10A/10A For AZZURRO 1PH 3000TLM-V1;**

**DC Input: DC 100 - 550V, 12A/12A For AZZURRO 1PH 3680TLM-V1;**

**DC Input: DC 100 - 550V, 13A/13A For AZZURRO 1PH 4000TLM-V1;**

**DC Input: DC 100 - 550V, 15A/15A For AZZURRO 1PH 4600TLM-V1;**

**DC Input: DC 100 - 550V, 15A/15A For AZZURRO 1PH 5000TLM-V1;**

**DC Input: DC 100 - 580V, 15A/15A For AZZURRO 1PH 6000TLM-V1**


**Output: AC 230V, 50/60Hz, Power: 3000VA / 3680VA / 4000VA / 4600VA / 5000VA / 6000VA**

**Output Voltage/Current: AZZURRO 1PH 3000TLM-V1:AC 230V/13A; AZZURRO**

**1PH 3680TLM-V1:AC 230V/16A; AZZURRO 1PH 4000TLM-V1: AC 230V/17.5A;**

**AZZURRO 1PH 4600TLM-V1: AC 230V/20A; AZZURRO 1PH 5000TLM-V1:AC**

**230V/22A ; AZZURRO 1PH 6000TLM-V1:AC 230V/26A**

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

- Electromagnetic Compatibility Directive 2014/30/EU

Standards	Report Number	Report date
EN 61000-6-3:2007 + A1:2011+ AC: 2012 EN IEC 61000-3-2:2019 EN 61000-3-3:2013+A1:2019 EN IEC 61000-3-11:2019 EN 61000-3-12:2011 EN 61000-6-2:2005	CE200709N001-5	Jan. 27, 2021

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product. The CE marking may be affixed if all relevant and effective European Directives with CE are applicable.

**Assistant Manager  
EMC Department**



**Name: Glyn He**

**Date: Jan. 27, 2021**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd.

Information given in this document is related to the tested specimen of the described electrical sample.

**Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch**

No. 96, Guantai Road (Houjie Section), Houjie  
Town, Dongguan City, Guangdong Province.  
523942. People's Republic of China.

Tel.: +86 769 8998 2098  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)