

CERTIFICATE

Of Conformity

Low Voltage Directive 2014/35/EU

Registration No.: **AT1811C502244122**

Report No.: **1811C50224412201**

Attachment of rating

Rating

: **AZZURRO 1PH 5000TL2-V3:**

PV Input

Max. Input Voltage: 600 Vd.c.
MPPT Voltage Range: 50-600 Vd.c.
Max. Input Current: 20 A
Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+ \oplus ,220/230 Va.c.
Rated Output Frequency: 50/60 Hz
Rated Output Power: 5000W
Max. Apparent Power: 5000VA
Max. Output Current:24.1A
Power Factor Range: 0.8 leading-0.8 lagging
Inverter Topology: Non-Isolation
Protective Class: Class I
IP Rating: IP65
Overvoltage Category: AC III, DC II

AZZURRO 1PH 4000TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.
MPPT Voltage Range: 50-550 Vd.c.
Max. Input Current: 20 A
Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+ \oplus ,220/230 Va.c.
Rated Output Frequency: 50/60 Hz
Rated Output Power: 4000W
Max. Apparent Power: 4000VA
Max. Output Current:19.3A
Power Factor Range: 0.8 leading-0.8 lagging
Inverter Topology: Non-Isolation
Protective Class: Class I
IP Rating: IP65
Overvoltage Category: AC III, DC II

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. The certificate does not imply assessment of the series-production of the product. The applicant of the certificate is authorized to use this certificate in connection with EU declaration of conformity specified in Article 15 and Annex IV of the Directive.



The CE Marking may only be used if all relevant and effective EU Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited
Sogood Industrial Zone Laboratory & 1/F. of Building D, Sogood Science and Technology Park,
Sanwei Community, Hangcheng Subdistrict, Bao'an District, Shenzhen, Guangdong, China.
Tel: (86)755-26066440 Email:service@anbotek.com



CERTIFICATE

Of Conformity

Low Voltage Directive 2014/35/EU

Registration No.: AT1811C502244122

Report No.: 1811C50224412201

Attachment of rating

Rating

: AZZURRO 1PH 3300TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.

MPPT Voltage Range: 50-550 Vd.c.

Max. Input Current: 20 A

Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+⊕,220/230 Va.c.

Rated Output Frequency: 50/60 Hz

Rated Output Power: 3300W

Max. Apparent Power: 3300VA

Max. Output Current:16A

Power Factor Range: 0.8 leading-0.8 lagging

Inverter Topology: Non-Isolation

Protective Class: Class I

IP Rating: IP65

Overvoltage Category: AC III, DC II

AZZURRO 1PH 3000TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.

MPPT Voltage Range: 50-550 Vd.c.

Max. Input Current: 20 A

Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+⊕,220/230 Va.c.

Rated Output Frequency: 50/60 Hz

Rated Output Power: 3000W

Max. Apparent Power: 3000VA

Max. Output Current:14.5A

Power Factor Range: 0.8 leading-0.8 lagging

Inverter Topology: Non-Isolation

Protective Class: Class I

IP Rating: IP65

Overvoltage Category: AC III, DC II

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. The certificate does not imply assessment of the series-production of the product. The applicant of the certificate is authorized to use this certificate in connection with EU declaration of conformity specified in Article 15 and Annex IV of the Directive.



The CE Marking may only be used if all relevant and effective EU Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited

Sogood Industrial Zone Laboratory & 1/F. of Building D, Sogood Science and Technology Park, Sanwei Community, Hangcheng Subdistrict, Bao'an District, Shenzhen, Guangdong, China.

Tel: (86)755-26066440

Email: service@anbotek.com



CERTIFICATE

Of Conformity

Low Voltage Directive 2014/35/EU

Registration No.: AT1811C502244122

Report No.: 1811C50224412201

Attachment of rating

Rating

: AZZURRO 1PH 2700TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.

MPPT Voltage Range: 50-550 Vd.c.

Max. Input Current: 20 A

Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+ \oplus ,220/230 Va.c.

Rated Output Frequency: 50/60 Hz

Rated Output Power: 2700W

Max. Apparent Power: 2700VA

Max. Output Current:13A

Power Factor Range: 0.8 leading-0.8 lagging

Inverter Topology: Non-Isolation

Protective Class: Class I

IP Rating: IP65

Overvoltage Category: AC III, DC II

AZZURRO 1PH 2200TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.

MPPT Voltage Range: 50-550 Vd.c.

Max. Input Current: 20 A

Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+ \oplus ,220/230 Va.c.

Rated Output Frequency: 50/60 Hz

Rated Output Power: 2200W

Max. Apparent Power: 2200VA

Max. Output Current:10.6A

Power Factor Range: 0.8 leading-0.8 lagging

Inverter Topology: Non-Isolation

Protective Class: Class I

IP Rating: IP65

Overvoltage Category: AC III, DC II

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. The certificate does not imply assessment of the series-production of the product. The applicant of the certificate is authorized to use this certificate in connection with EU declaration of conformity specified in Article 15 and Annex IV of the Directive.



The CE Marking may only be used if all relevant and effective EU Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited

Sogood Industrial Zone Laboratory & 1/F. of Building D, Sogood Science and Technology Park, Sanwei Community, Hangcheng Subdistrict, Bao'an District, Shenzhen, Guangdong, China.

Tel: (86)755-26066440

Email: service@anbotek.com



CERTIFICATE

Of Conformity

Low Voltage Directive 2014/35/EU

Registration No.: AT1811C502244122

Report No.: 1811C50224412201

Attachment of rating

Rating

: AZZURRO 1PH 1600TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.
MPPT Voltage Range: 50-550 Vd.c.
Max. Input Current: 20 A
Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+ \oplus ,220/230 Va.c.
Rated Output Frequency: 50/60 Hz
Rated Output Power: 1600W
Max. Apparent Power: 1600VA
Max. Output Current:7.7A
Power Factor Range: 0.8 leading-0.8 lagging
Inverter Topology: Non-Isolation
Protective Class: Class I
IP Rating: IP65
Overvoltage Category: AC III, DC II

AZZURRO 1PH 1100TL2-V3:

PV Input

Max. Input Voltage: 550 Vd.c.
MPPT Voltage Range: 50-550 Vd.c.
Max. Input Current: 20 A
Max.Isc:25 A

AC Output

Rated Output Voltage: L+N+ \oplus ,220/230 Va.c.
Rated Output Frequency: 50/60 Hz
Rated Output Power: 1100W
Max. Apparent Power: 1100VA
Max. Output Current:5.3A
Power Factor Range: 0.8 leading-0.8 lagging
Inverter Topology: Non-Isolation
Protective Class: Class I
IP Rating: IP65
Overvoltage Category: AC III, DC II

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. The certificate does not imply assessment of the series-production of the product. The applicant of the certificate is authorized to use this certificate in connection with EU declaration of conformity specified in Article 15 and Annex IV of the Directive.



The CE Marking may only be used if all relevant and effective EU Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited
Sogood Industrial Zone Laboratory & 1/F. of Building D, Sogood Science and Technology Park,
Sanwei Community, Hangcheng Subdistrict, Bao'an District, Shenzhen, Guangdong, China.
Tel: (86)755-26066440 Email:service@anbotek.com

