

Certificate of Conformity

Certificate Number: CN-PV-200173

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specification/standard at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Zucchetti Centro Sistemi SpA

Via Lungarno 305/A 52028 Terranuova Bracciolini (AR) Italy

Product: Solar Grid-tied Inverter

Ratings & Principle See Annex to Certificate of Conformity

Characteristics: Model:

AZZURRO 1PH 3000TLM-V2, AZZURRO 1PH 3680TLM-V2, AZZURRO 1PH 4000TLM-V2, AZZURRO 1PH 4600TLM-V2, AZZURRO 1PH 6000TLM-V2

Brand Name:

72CS

Tested according to:BOE 254:2006 ANNEX P.O.12.3 Testing of LVRT behaviour

Requirements for response to voltage dips in wind installations

Certificate Issuing Office Name &

Address:

Intertek Testing Services Ltd. Shanghai

West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free

Trade Zone, Shanghai, P. R. China

Test Report No.: 201022054GZU-002

Additional information in Appendix.

Signature

Certification Manager: Grady Ye

/ sur (u

Date: 24 December 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200173

Ratings & Principle Characteristics:

Model	AZZURRO 1PH 3000TLM-V2	AZZURRO 1PH 3680TLM-V2	AZZURRO 1PH 4000TLM-V2	AZZURRO 1PH 4600TLM-V2	
	Input				
Max. DC input Voltage:	600V				
Max. input current:	2*11A				
PV Isc	2*13.2 A				
Output					
Nominal AC output voltage:	230Vac				
Nominal frequency:	50Hz				
Max AC output power (@PF=1)	3000W	3680W	4000W	4600W	
Max AC output power	3000VA	3680VA	4000VA	4600VA	
Nominal AC output current:	13.7A	16.8A	18.2A	21.0A	
Power factor:	0.8 Leading to 0.8 Lagging				
Ingress protection:	IP65				
Protection Class:	Class I				
Operation Ambient Temp	-25°C to +60°C				
Software Version	V2.00				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200173

Ratings & Principle Characteristics:

Model	AZZURRO 1PH 5000TLM-V2	AZZURRO 1PH 6000TLM-V2			
Input					
Max. DC input Voltage:	600V				
Max. input current:	2*11A				
PV Isc	2*13.2A				
Output					
Nominal AC output voltage:	230	230Vac			
Nominal frequency:	50	50Hz			
Max AC output power (@PF=1)	5000W	6000W			
Max AC output power	5000VA	6000VA			
Nominal AC output current:	22.8A	27.3A			
Power factor:	0.8 Leading	0.8 Leading to 0.8 Lagging			
Ingress protection:	IP65				
Protection Class:	Class I				
Operation Ambient Temp	-25°C to +60°C				
Software Version	V2.00				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.