



# Certificate of Conformity

Certificate Number: CN-PV-230626

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Zucchetti Centro Sistemi SpA Via Lungarno 305/A 52028 Terranuova Bracciolini (AR) Italy
<b>Product:</b>	Solar Grid-tied Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	AZZURRO 3PH 25KTL-V3, AZZURRO 3PH 30KTL-V3, AZZURRO 3PH 30KTL-V3-A, AZZURRO 3PH 33KTL-V3, AZZURRO 3PH 36KTL-V3, AZZURRO 3PH 40KTL-V3, AZZURRO 3PH 45KTL-V3, AZZURRO 3PH 50KTL-V3, AZZURRO 3PH 40KTL-V3-HV, AZZURRO 3PH 50KTL-V3-HV
<b>Brand Name&lt;s&gt;:</b>	
<b>Product Complies with:</b>	UTE C 15-712-1:2013 DIN V VDE V 0126-1-1:2013 Enedis-PRO-RES_10E version 5
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China  Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	231103040GZU-001, 14 November 2023 231103040GZU-002, 14 November 2023

Additional information in Appendix.



Signature

**Certification Manager: Grady Ye**  
**Date: 20 November 2023**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230626.

Model	AZZURRO 3PH 25KTL-V3	AZZURRO 3PH 30KTL-V3	AZZURRO 3PH 30KTL-V3-A
Max. DC input Voltage	1100Vdc		
Operating MPPT voltage range	180Vdc – 1000Vdc		
Max. Input current	40A*3		
PV Isc	50A*3		
Nominal AC output voltage	3/N/PE 230Vac/400Vac		
Nominal AC output Frequency	50Hz		
Max. AC output current	42.4A	51.5A	45.3A
Nominal Output power	25000W	30000W	29900W
Max.Output Power	28000VA	34000VA	29900VA
Power factor	1(adjustable +/-0.8)		
Safety level	Class I		
Ingress Protection	IP 65		
Operation Ambient Temperature	-30°C - 60°C		
Software version	V000001		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230626.

Model	AZZURRO 3PH 33KTL-V3	AZZURRO 3PH 36KTL-V3	AZZURRO 3PH 40KTL-V3
Max. DC input Voltage	1100Vdc		
Operating MPPT voltage range	180Vdc – 1000Vdc		
Max. Input current	40A*3		40A*4
PV Isc	50A*3		50A*4
Nominal AC output voltage	3/N/PE 230Vac/400Vac		
Nominal AC output Frequency	50Hz		
Max. AC output current	56A	60.6A	66.7A
Nominal Output power	33000W	36000W	40000W
Max.Output Power	37000VA	40000VA	44000VA
Power factor	1(adjustable +/-0.8)		
Safety level	Class I		
Ingress Protection	IP 65		
Operation Ambient Temperature	-30°C - 60°C		
Software version	V000001		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230626.

Model	AZZURRO 3PH 45KTL-V3	AZZURRO 3PH 50KTL-V3	AZZURRO 3PH 40KTL-V3-HV	AZZURRO 3PH 50KTL-V3-HV
Max. DC input Voltage	1100Vdc			
Operating MPPT voltage range	180Vdc – 1000Vdc			
Max. Input current	40A*4		40A*3	40A*4
PV Isc	50A*4		50A*3	50A*4
Nominal AC output voltage	3/N/PE 230Vac/400Vac		3/N/PE 277Vac/480Vac	
Nominal AC output Frequency	50Hz			
Max. AC output current	75.8A	83.3A	53.0A	66.2A
Nominal Output power	45000W	50000W	40000W	50000W
Max.Output Power	50000VA	55000VA	44000VA	55000VA
Power factor	1(adjustable +/-0.8)			
Safety level	Class I			
Ingress Protection	IP 65			
Operation Ambient Temperature	-30℃ - 60℃			
Software version	V000001			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.